TOWN OF VERNON

14 PARK PLACE, VERNON, CONNECTICUT 06066

OFFICE OF PERMANENT MUNICIPAL
BUILDING COMMITTEE

Office of the Permanent Municipal Building Committee

APPROVED MINUTES

Special Meeting: March 28, 2018   6:00 P.M.   Fire Station #4 (Nye St.), #5 (Prospect St.)

Attendees: John Leary, George Greco, Joe Greco, Jason Mistretta

The meeting was called to order at 6:54 p.m. by John Leary after an inspection of Fire Stations #4 and #5.

APPROVAL OF MINUTES:

A motion to approve the Minutes of the regular meeting of February 21, 2018 was made by Joe Greco, seconded by George Greco, and unanimously approved.

CITIZENS FORUM: None

ANNUAL INSPECTION OF TOWN BUILDINGS:

A motion to approve the inspection report for Fire Stations #1, #2 and #3 was made by George Greco, seconded by Joe Greco, and unanimously approved.

ANY OTHER BUSINESS: None

The meeting was adjourned at 7:20 p.m. with a motion made by Joe Greco, seconded by Jason Mistretta, and unanimously approved.

Julie A. Mathison

Julie A. Mathison, Recording Secretary

INSPECTION OF TOWN BUILDINGS
FIRE STATIONS #4 & #5
PERFORMED BY THE PERMANENT MUNICIPAL BUILDING COMMITTEE
MARCH 28, 2018

FIRE STATION #4 – NYE STREET:

1. The repointing around the chimney must be done. This item was stated in the Inspection Report of March 23, 2016.

2. The outside grates need a mesh covering to stop the leaves from falling into the pit for fresh air intake.

3. The sump hole in the cellar needs to be cleaned out.

4. Side weather stripping is needed on the bay doors.

5. The light on the flag pole should be changed out to LED.

6. The fire alarm system must be checked in this building.

FIRE STATION #5 – PROSPECT STREET:

1. A new roof with a hatch for access is still needed. This item was stated in the Inspection Report of March 23, 2016.

2. The bathroom must be upgraded, especially the shower.

3. The building should be examined to ensure it meets life safety codes.

4. The fire alarm system must be checked in this building.